


STP-NU-038

INTERMEDIATE HEAT EXCHANGER (IHX)



STP-NU-038

ASME CODE CONSIDERATIONS FOR THE INTERMEDIATE HEAT EXCHANGER (IHX)



Date of Issuance: September 24, 2010

This report was prepared as an account of work sponsored by the U.S. Department of Energy (DOE) and the ASME Standards Technology, LLC (ASME ST-LLC).

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer or otherwise does not necessarily constitute or imply its endorsement, recommendation or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Neither ASME, ASME ST-LLC, the author nor others involved in the preparation or review of this report, nor any of their respective employees, members or persons acting on their behalf, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe upon privately owned rights.

Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer or otherwise does not necessarily constitute or imply its endorsement, recommendation or favoring by ASME ST-LLC or others involved in the preparation or review of this report, or any agency thereof. The views and opinions of the authors, contributors and reviewers of the report expressed herein do not necessarily reflect those of ASME ST-LLC or others involved in the preparation or review of this report, or any agency thereof.

ASME ST-LLC does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a publication against liability for infringement of any applicable Letters Patent, nor assumes any such liability. Users of a publication are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this publication.

ASME is the registered trademark of the American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

ASME Standards Technology, LLC
Three Park Avenue, New York, NY 10016-5990

ISBN No. 978-0-7918-3336-0

Copyright © 2010 by
ASME Standards Technology, LLC
All Rights Reserved

TABLE OF CONTENTS

Foreword	vii
Abstract	viii
PART I	1
1 INTRODUCTION	2
2 SCOPE	3
3 REVIEW OF DIFFERENT IHX CONCEPTS	4
3.1 Tubular Helical Coil Heat Exchanger (THCHE)	4
3.1.1 KVK Tubular Helical Coil IHX	4
3.1.2 HTTR Tubular IHX	6
3.2 Compact IHX	7
3.2.1 PSHE	7
3.2.2 PMHE	9
3.2.3 PFHE	10
3.2.4 Two Stage IHX Concept	11
4 Maturity of the Concepts	12
4.1 Tubular Helical Coil Heat Exchanger Maturity	12
4.1.1 Design.....	12
4.1.2 Fabricability	14
4.1.3 Component Testing	15
4.1.4 Feasibility of AREVA Concept.....	17
4.2 PSHE Maturity	17
4.2.1 Design.....	17
4.2.2 Fabricability	18
4.2.3 Component testing.....	19
4.2.4 Discussion on Feasibility.....	19
4.3 PMHE Maturity	20
4.3.1 Design.....	20
4.3.2 Fabricability	20
4.3.3 Component Testing	20
4.3.4 Discussion on Feasibility.....	20
4.4 PFHE Maturity	21
4.4.1 Design.....	21
4.4.2 Fabricability	21
4.4.3 Component Testing	21
4.4.4 Discussion on Feasibility.....	21
5 SURVEY	22
6 MATERIAL CANDIDATES FOR IHX APPLICATIONS	23
6.1 Identification of Candidate Materials.....	23
6.1.1 Recommendations of Reactor Vendors.....	23
6.1.2 Other Alternatives	23
6.2 Primary Issues in Materials Selection	26
6.2.1 Core Outlet Temperature.....	26
6.2.2 Creep Rupture	26

6.2.3	Creep-Fatigue.....	27
6.2.4	Weldability.....	27
6.2.5	Microstructural Stability.....	27
6.2.6	Corrosion	27
6.3	Issues to be Addressed for Codification	28
6.3.1	Acceptable Materials of Construction	28
6.3.2	Maximum Temperature	29
6.3.3	Maximum Design Life.....	29
6.3.4	Nonclassical Creep	29
6.3.5	Environmental Effects	30
6.3.6	Possible New Failure Mode.....	30
7	Conclusions	31
	References - PART I.....	32
	PART II.....	34
1	INTRODUCTION	35
2	CONSIDERED DESIGNS FOR HTR IHX	36
2.1	Helical Tube Design	36
2.2	Compact Stacked Plate IHX designs	36
3	KEY FEATURES OF A CONSTRUCTION CODE	37
3.1	Introduction.....	37
3.2	High Temperature Code Development in the U.S.....	37
3.3	High Temperature Code Development in Germany	39
3.4	High Temperature Code Development in Japan.....	41
3.5	Other Heat Exchanger Code Development.....	42
3.6	Considerations on Safety Classification of the IHX	43
3.7	Issues Raised By the NRC in the Context of High Temperature Design.....	43
3.8	Discussion on the Key Features to be Introduced.....	44
3.8.1	Design	44
3.8.2	Material.....	45
3.8.3	Fabrication	50
3.8.4	Examination of Joints (NDE).....	52
4	TESTS REQUIRED FOR THE QUALIFICATION OF DESIGN METHODS.....	53
4.1	Standard Tests and Extension of Corresponding Database.....	53
4.2	Tests After Thermal Aging	53
4.3	Tests in HTR Helium Environment	53
4.4	Tests on Weldments.....	53
4.5	Mock-Ups to be Tested.....	53
5	REQUIRED IN-SERVICE INSPECTION AND ASSOCIATED NDE.....	54
5.1	Introduction.....	54
5.2	Current PWR ISI Requirements.....	55
5.3	KVK (German) HTR Heat Exchanger ISI Experience	55
5.4	Feasibility of NDE for the Shell and Tube IHX	56

5.5 Compact Heat IHX.....	56
5.6 Conclusion of ISI Requirements	57
6 ADEQUACY OF EXISTING ASTM SPECIFICATIONS.....	58
6.1 Standards for Materials	58
6.1.1 Chemical Composition.....	59
6.1.2 Mechanical Properties.....	59
6.1.3 Dimensions.....	60
6.1.4 Heat Treatment.....	61
6.1.5 Conclusions for Material Specifications	61
6.2 Standards for Testing.....	63
6.2.1 Time-Independent Data.....	63
6.2.2 Time-Dependent Data	63
6.2.3 Toughness Data	64
6.2.4 External Pressure Data	64
6.2.5 Cyclic Service Data	65
6.2.6 Other Data	65
6.2.7 Conclusions for ASTM Testing Specifications.....	67
7 RECOMMENDATIONS IN TERMS OF CODE INFRASTRUCTURE	69
8 CONCLUSIONS	70
References - PART II	71
Appendix A - RETURNED SURVEYS.....	73
Appendix B - PERTINENT DOCUMENT LIST	79
Acknowledgments	81
Abbreviations and Acronyms	82

LIST OF TABLES

Table 1 - Parameters of KVK Tubular IHX	5
Table 2 - HTTR Tubular IHX Parameters.....	7
Table 3 - Compositions of Candidate Materials for IHX	25
Table 4 - Mechanical Tests on Hastelloy XR.....	42
Table 5 - Specified Chemical Analysis of HTR IHX Alloys	47
Table 6 - Code Status of the Different IHX Alloys	47
Table 7 - Selected ASTM Specifications for Alloys 617 and 230	58
Table 8 - ASTM Standards for Measuring Time-Independent Properties of Materials	63
Table 9 - ASTM Standards for Measuring Time-Dependent Properties of Materials.....	64
Table 10 - ASTM Standards for Measuring Toughness Properties of Materials	64
Table 11 - ASTM Standards for Measuring Stress-Strain Curves of Materials	65
Table 12 - ASTM Standards for Measuring Cyclic Service Properties of Materials	65
Table 13 - ASTM Standards for Measuring Thermal Properties of Materials	66
Table 14 - ASTM Standards for Measuring Elastic Properties of Materials.....	67

LIST OF FIGURES

Figure 1 - Typical Flow of the Tubular IHX	5
Figure 2 - JAERI Tubular IHX Design.....	6
Figure 3 - PSHE	8
Figure 4 - PMHE.....	9
Figure 5 - PFHE	10
Figure 6 - Dual Stage IHX	11
Figure 7 - Misdistribution	12
Figure 8 - Hot Header	14
Figure 9 - Possible Weld Type in a Tubular IHX	15
Figure 10 - View of 10MWth Mock-up for KVK Facility	16
Figure 11 - Stamped Plate.....	19
Figure 12 - Ceramic Compact Heat Exchanger Using Ceramatec's LOM Process.....	25
Figure 13 - Creep-Rupture Strength of Alloys 617 and 230 as a Function of Temperature and Time to Fail.....	26
Figure 14 - Schematic of Classical Creep Strain as a Function of Time	29
Figure 15 - Schematic of Nonclassical Creep Strain as a Function of Time	30
Figure 16 - Comparison Creep Stress to Rupture	41
Figure 17 - Typical Compact IHX Module Arrangement.....	54
Figure 18 - Typical Tubular IHX.....	55
Figure 19 - Schematic of KVK Eddy Current Delivery in the Helical IHX	56

FOREWORD

This document is the result of work resulting from Cooperative Agreement DE-FC07-05ID14712 between the U.S. Department of Energy (DOE) and ASME Standards Technology, LLC (ASME ST-LLC) for the Generation IV (Gen IV) Reactor Materials Project. The objective of the project is to provide technical information necessary to update and expand appropriate ASME materials, construction and design codes for application in future Gen IV nuclear reactor systems that operate at elevated temperatures. The scope of work is divided into specific areas that are tied to the Generation IV Reactors Integrated Materials Technology Program Plan. This report is the result of work performed under Task 7 titled “ASME Code Considerations for the Intermediate Heat Exchanger (IHX).”

ASME ST-LLC has introduced the results of the project into the ASME volunteer standards committees developing new code rules for Generation IV nuclear reactors. The project deliverables are expected to become vital references for the committees and serve as important technical bases for new rules. These new rules will be developed under ASME’s voluntary consensus process, which requires balance of interest, openness, consensus and due process. Through the course of the project, ASME ST-LLC has involved key stakeholders from industry and government to help ensure that the technical direction of the research supports the anticipated codes and standards needs. This directed approach and early stakeholder involvement is expected to result in consensus building that will ultimately expedite the standards development process as well as commercialization of the technology.

ASME has been involved in nuclear codes and standards since 1956. The Society created Section III of the Boiler and Pressure Vessel Code, which addresses nuclear reactor technology, in 1963. ASME Standards promote safety, reliability and component interchangeability in mechanical systems.

Established in 1880, the American Society of Mechanical Engineers (ASME) is a professional not-for-profit organization with more than 127,000 members promoting the art, science and practice of mechanical and multidisciplinary engineering and allied sciences. ASME develops codes and standards that enhance public safety, and provides lifelong learning and technical exchange opportunities benefiting the engineering and technology community. Visit www.asme.org for more information.

The ASME Standards Technology, LLC (ASME ST-LLC) is a not-for-profit Limited Liability Company, with ASME as the sole member, formed in 2004 to carry out work related to newly commercialized technology. The ASME ST-LLC mission includes meeting the needs of industry and government by providing new standards-related products and services, which advance the application of emerging and newly commercialized science and technology and providing the research and technology development needed to establish and maintain the technical relevance of codes and standards. Visit www.stllc.asme.org for more information.

ABSTRACT

Part I - Review of Current Experience on Intermediate Heat Exchanger

This report will first review the different concepts of intermediate heat exchanger (IHX) that could be envisioned for HTR/VHTR applications in a range of temperatures from 850 to 950°C. This will cover shell-and-tube and compact designs (including the plate-fin concept). The review will then discuss the maturity of the concepts in terms of design, fabricability and component testing. This report will also discuss material candidates for IHX applications and will discuss specific issues that will have to be addressed in the context of the HTR design.

Part II - Recommended Code Approach for Intermediate Heat Exchanger

This report is providing recommendations in terms of Code approach for the Intermediate Heat Exchangers envisioned for High Temperature Gas-Cooled Reactors. The report will address the following:

- Recommend key features of a construction code needed to address the unique issues associated with the VHTR IHX and associated equipment
- Identify the tests which should be required to establish cyclic life or to calibrate design methods
- Identify required in-service inspection and associated NDE
- Review the adequacy of existing ASTM specifications for materials, testing, examination, etc. to determine if any new standards will need to be developed to support IHX design, fabrication, operation or inspection.
- Provide recommendations in terms of Code infrastructure.