

ASME A120.1-2021
(Revision of ASME A120.1-2014)

Safety Requirements for Powered Platforms and Traveling Ladders and Gantries for Building Maintenance

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME A120.1-2021
(Revision of ASME A120.1-2014)

Safety Requirements for Powered Platforms and Traveling Ladders and Gantries for Building Maintenance

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: May 31, 2022

The next edition of this Standard is scheduled for publication in 2026. This Standard will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2022 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	iv
Committee Roster	v
Correspondence With the A120 Committee	vi
Summary of Changes	viii
1 General Recommendations and Definitions	1
2 Building Design Requirements	6
3 Equipment Design and Construction Requirements	9
4 Traveling Ladders and Gantries	27
5 Inspections, Tests, Operation, and Maintenance	28
Mandatory Appendices	
I Operating Manual Layout	32
II Minimum Requirements for Pre-use/30-Day Maintenance Inspections	34
Nonmandatory Appendix	
A Typical Intermittent Stabilization System	36
Figures	
3.5.1-1 Guide for Davit Raising Clearances	16
A-1 Typical Intermittent Stabilization System	37
Tables	
3.2.9-1 Minimum Clearance for Operation of Equipment Near High-Voltage Power Lines	13
4.3.2-1 Access	27