

ASME CSD-1–2021
(Revision of ASME CSD-1–2018)

Controls and Safety Devices for Automatically Fired Boilers

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME CSD-1-2021
(Revision of ASME CSD-1-2018)

Controls and Safety Devices for Automatically Fired Boilers

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: November 17, 2021

The next edition of this Standard is scheduled for publication in 2024.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME CSDAFB Committee may be published as Cases. Cases and interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2021 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword		v
Committee Roster		vi
Correspondence With the CSDAFB Committee		vii
Summary of Changes		ix
Part CG	General	1
CG-100	General Requirements	1
CG-200	General Provisions	2
CG-300	Material Requirements	2
CG-400	Testing and Maintenance	2
CG-500	Certification and Reporting	3
CG-600	Operation	3
CG-700	Definitions	3
Part CM	Testing and Maintenance	10
CM-100	Periodic Testing and Maintenance	10
Part CE	Electrical	11
CE-100	Electrical Requirements	11
Part CW	Steam and Waterside Control	13
CW-100	Automatic Low-Water Fuel Cutoff and/or Combined Water Feeding Device	13
CW-200	Automatic Fuel Cutoff for Forced Circulation Boilers	15
CW-300	Pressure Controls	15
CW-400	Temperature Controls	16
CW-500	Safety and Safety Relief Valves	17
CW-600	Modular Boilers	17
CW-700	Vacuum Boilers	17
Part CF	Combustion Side Control	19
CF-100	Gas-Fired Boiler Units, Equipment	19
CF-200	Gas-Fired Boiler Units, Purging	28
CF-300	Gas-Fired Boiler Units, Safety Controls	29
CF-400	Oil-Fired Boiler Units, Equipment	30
CF-500	Oil-Fired Boiler Units, Safety Controls	31
CF-600	Low Fire Start, Gas- or Oil-Fired Boiler Units	33
CF-700	Combination Gas- and Oil-Fired Units	33
CF-800	Electrically Heated Boilers	33
CF-900	Combustion Side Controls for Modular Boilers	33
 Nonmandatory Appendices		
A	Comparison of This Standard and ANSI Z21.13/CSA 4.9	35
B	Typical Fuel Trains	36

C	Manufacturer's/Installing Contractor's Report for ASME CSD-1	47
D	Recommended Preventive Maintenance Schedule	50
E	References	55
F	Guidance for the Use of U.S. Customary and SI Units in ASME CSD-1	56

Figures

CG-700-1	Sediment Trap	8
B-1	Typical Gas Fuel Train With Pilot Ignition System and Atmospheric Burners [Greater Than 400,000 Btu/hr (117 kW) and Less Than or Equal to 2,500,000 Btu/hr (733 kW)]	37
B-2	Typical Gas Fuel Train With Pilot Ignition System [Greater Than 400,000 Btu/hr (117 kW) and Less Than or Equal to 2,500,000 Btu/hr (733 kW)]	38
B-3	Typical Gas Fuel Train With Direct Ignition System [Greater Than 400,000 Btu/hr (117 kW) and Less Than or Equal to 2,500,000 Btu/hr (733 kW)]	40
B-4	Typical Gas Fuel Train With Pilot Ignition System [Greater Than 2,500,000 Btu/hr (733 kW) and Less Than or Equal to 5,000,000 Btu/hr (1 465 kW)]	41
B-5	Typical Gas Fuel Train With Pilot Ignition System [Greater Than 5,000,000 Btu/hr (1 465 kW) and Less Than 12,500,000 Btu/hr (3 663 kW)]	43
B-6	Typical Gas Fuel Train With Pilot Ignition System and Negative (Zero Governor) Main Manifold Gas Pressure [Greater Than 400,000 Btu/hr (117 kW) and Less Than 12,500,000 Btu/hr (3 663 kW)]	44
B-7	Typical Gas Fuel Train With Direct Ignition System and Negative (Zero Governor) Main Manifold Gas Pressure [Greater Than 400,000 Btu/hr (117 kW) and Less Than 12,500,000 Btu/hr (3 663 kW)]	45
B-8	Typical Oil Fuel Train	45
B-9	Example for Sizing of Manifolder Lines	46
B-10	Typical Gas Fuel Train Safety Shutoff Valve Arrangements for Multiple-Burner Boiler Units Complying With CF-180(b)	46

Tables

CF-110-1	400,000 Btu/hr (117 kW) and Smaller (Gas — Natural Draft)	20
CF-110-2	400,000 Btu/hr (117 kW) and Smaller (Power Gas Burners, Mechanical Draft Atmospheric Gas Burners, and Pulse Combustion Systems), 3 gph (11.4 L/h) [Approximately 400,000 Btu/hr (117 kW)] and Smaller (Oil)	21
CF-162-1	Safety Controls for Automatically Fired Units: Power Gas Burners, Mechanical Draft Atmospheric Gas Burners, and Pulse Combustion Systems	23
CF-162-2	Safety Controls for Automatically Fired Units: Atmospheric Gas Burners — Natural Draft	25
CF-460-1	Safety Controls for Automatically Fired Units: Oil-Fired Burners	32
B-1	Figure Index	36
D-1-1	Periodic Testing Recommended Checklist	52